

				GHK_PP-1-1609 250A 347/600V. 3PH 4FILS					 UNIVERSITÉ LAVAL Service des immeubles			 CUTLER HAMMER P3A 18KA KRUGER Classe N/A						
WATTS		DISJ.												DISJ.		WATTS		
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC					
				LIBRE	15	1	2	15	LIBRE									
				LIBRE	15	3	4	15	ECL.1502									
				ECL.1530	15	5	6	15	ECL.1516									
				1535,1611A,1521,1505,1503	15	7	8	15	ECL.1554,1550									
				1576,1566,1570	15	9	10	15	LIBRE									
				LIBRE	15	11	12	15	LIBRE									
				ESPACE		13	14		ESPACE									
				ESPACE		15	16		ESPACE									
				ESPACE		17	18		ESPACE									
				ESPACE		19	20		ESPACE									
				ESPACE		21	22		ESPACE									
				ESPACE		23	24		ESPACE									
				ESPACE		25	26		ESPACE									
				ESPACE		27	28		ESPACE									
				ESPACE		29	30		ESPACE									
				POMPE CYLINDRE	15	31	32		ESPACE									
				SATURATION	15	33	34		ESPACE									
				1515	15	35	36		ESPACE									
				SERPENTIN	30	37	38	20	LIBRE									
				AUTOCLAVE	30	39	40	20	VERS									
				1515	30	41	42	20	SECT-1515									
0	0	0		TOTAL		0					0	0	0					