



				DKN-PS-1-1444 200 A 120/208 Volts 3 PH, 4 FILS					 UNIVERSITÉ LAVAL <small>Service des immeubles</small>		 Classe N/A		Westinghouse NPLB					
WATTS		DISJ.							De Koninck		DISJ.		WATTS					
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC					
				Lum. 1431-35	15	1	2	15	Prise 1446									
				Lum. 1431-35	15	3	4	15	OCCUPÉ									
				Lum. 1437-41	15	5	6	15	LIBRE									
				Lum. 1437-41	15	7	8	15	OCCUPÉ									
				Lum. 1445-49	20	9	10	15	Lum. 1426									
				Lum. 1445-49	15	11	12	15	Lum. 1444									
				Lum. 1451-55	15	13	14	15	Lum. 1446-48									
				LIBRE	15	15	16	15	Lum. 1446-48									
				LIBRE	20	17	18	15	Lum. 1448-54									
				LIBRE	20	19	20	15	Lum. 1448-54									
				PC passage	30	21	22	15	LIBRE									
				Éclairage passage	15	23	24	15	OCCUPÉ									
				Prise 1437-45-48-49	15	25	26	15	OCCUPÉ									
				Prise 1451-55	15	27	28	15	LIBRE									
				Prise 1445-49-51-55	15	29	30	15	OCCUPÉ									
				Lum. Téléphone	15	31	32	15	Prise 1448-54									
				Prise 1446-48	15	33	34	20	PC TOILETTE									
				LIBRE	20	35	36	20 20	Prise 1431-35									
				OCCUPÉ	20 20	37	38	20	OCCUPÉ									
				LIBRE	20	39	40	20	OCCUPÉ									
				Lumière passage	15	41	42	20	OCCUPÉ									
0	0	0		TOTAL		0					0	0	0					

RÉFÉRENCE SEULEMENT