

				CHM-CDS-1-00251				UNIVERSITÉ LAVAL		WESTINGHOUSE					
				600 Ampères				UNIVERSITÉ LAVAL		Type PL-4					
				120/208 VOLTS				Service des immeubles		Classe N/A		TYPE DISJ. MARCHAND			
				3 PH, 4 FILS								DISJ. WATTS			
WATTS		DISJ.													
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC		
				PS-4-00200	150			150	PS-2-00200						
			HFD3150 / 100KA	"	150	1	2	150	"	HFD3150 / 100KA					
				"	150			150	"						
				PS-3-00200	150			150	LIBRE						
			HFD3150 / 100KA	"	150	3	4	150	"	HFD3150 / 100KA					
				"	150			150	"						
				ESPACE				200	PS-3-00211						
				"		5	6	200	"	CAH3200W/ 22KA					
				"				200	"						
				LIBRE	150				ESPACE						
			HFD3150 / 100KA	"	150	7	8		"						
				"	150				"						
				ESPACE					"						
				"		9	10		"						
				"					"						
				"					"						
				"		11	12		"						
				"					"						
				"					"						
				"		13	14		"						
				"					"						
0	0	0		TOTAL		0					0	0	0		

				CHM-CDS-1-00251					WESTINGHOUSE				
				600 Ampères					Type PL-1				
				120/208 VOLTS					Classe				
				3 PH, 4 FILS					N/A				
WATTS		DISJ.							DISJ.		WATTS		
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC
				ESPACE					ESPACE				
				ESPACE	15		16		ESPACE				
				ESPACE					ESPACE				
				X					DISJONCTEUR	HLD3600F			
							18	600	PRINCIPAL	AJUST. 600A			
									HLD3600F	100 KA			
0	0	0		TOTAL			0				0	0	0