



				CHM-PS-2-00200 225 Ampères 120/208 VOLTS 3 PH, 4 FILS					 UNIVERSITÉ LAVAL Service des immeubles		 WESTINGHOUSE Type PL-1 Classe N/A		TYPE DISJ. MARCHAND				
WATTS			DISJ.											DISJ.	WATTS		
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC				
				ESPACE		1	2	20 DDFT	PC 00209 (U:C9)								
				"		3	4	20	Écl. 00209 contrôlé (U:C9)								
				PC 00235 (Hotte chimique)	15	5	6		ESPACE								
				PC 00235	15	7	8		"								
				PC 00235	15	9	10		"								
				PC 00235 (comptoir)	15	11	12		"								
				PC 00235	15	13	14	15	LIBRE								
				PC 00235	15	15	16	15	"								
				PC 00235	30	17	18	15	"								
				PC 00235	30	19	20		ESPACE								
				ESPACE		21	22		"								
				Chauf/ REF Procédé	20 DDFT	23	24		"								
				L-00208 (U:C1)	20 DDFT	25	26		"								
				Chauf/ REF Procédé	20 DDFT	27	28	15	LIBRE								
				L-00210 (U:C2)	20 DDFT	29	30	15	"								
			DDFT	Chauf/ REF Procédé	20 DDFT	31	32		ESPACE								
			DDFT	L-00210 (U:C3)	20 DDFT	33	34		"								
			DDFT	Chauf/ REF Procédé	20 DDFT	35	36		"								
			DDFT	L-00210 (U:C4)	20 DDFT	37	38		"								
				Chauf/ REF Procédé	20 DDFT	39	40		"								
				L-00210 (U:C5)	20 DDFT	41	42		"								
0	0	0		TOTAL		0					0	0	0				