

				CHM-PS-2-00211					WESTINGHOUSE								
				225 Ampères					Type PL-1								
				120/208 VOLTS					TYPE DISJ.								
				3 PH, 4 FILS					MARCHAND								
				Service des immeubles					Classe N/A								
				UNIVERSITÉ LAVAL					WESTINGHOUSE								
				Service des immeubles					Type PL-1								
				Classe N/A					TYPE DISJ.								
				MARCHAND					DISJ.					WATTS			
				DISJ.					WATTS								
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC				
				PC Plafond 00201 (BASSIN #1, U:B1)	15 DDFT	1	2	15 DDFT	PC Colonette 00201 (U:B4)								
				PC Plafond 00201 (BASSIN #1, U:B1)	15 DDFT	3	4	15 DDFT	PC Colonette 00201 (U:B3)								
				PC Plafond 00201 (BASSIN #2, U:B1)	15 DDFT	5	6	15 DDFT	PC Colonette 00201 (U:B3)								
				PC Plafond 00201 (BASSIN #2, U:B1)	15 DDFT	7	8	15 DDFT	PC Colonette 00201 (U:B4)								
				PC Plafond 00201 (BASSIN #2, U:B1)	15	9	10	15 DDFT	PC Colonette 00201 (U:B5)								
				PC 00201 (U:B1)	15	11	12	15 DDFT	PC Colonette 00201 (U:B5)								
				Spare BJ Plafond 00201 (Allée U:B1)	30	13	14	15	PC 00201 (Allée U:B5, BASSIN #2 U:B1)								
				Chauf/Ref (Procédé)	20 DDFT	15	16	15	Pomp. 1,5 HP								
				00201 (U:B4)	20 DDFT	17	18	15	Local 00201								
				ESPACE		19	20	15	(Échangeur UB:1)								
				Spare BJ 00201	20	21	22	30	Chauf/Ref (Procédé)								
				(U:B4)	20	23	24	30	00201 (U:B1)								
				ESPACE		25	26		ESPACE								
				Chauf/Ref (Procédé)	20	27	28	15	LIBRE								
				00201 (U:B5)	20	29	30	15	"								
				ESPACE		31	32	15	"								
				LIBRE	15	33	34	15	"								
				Convion	60	35	36	40	LIBRE								
				Local 00246	60	37	38	40	"								
					60	39	40	40	"								
				ESPACE		41	42		ESPACE								
0	0	0		TOTAL		0					0	0	0				