



				CHM-PS-3-00211 225 Ampères 120/208 VOLTS 3 PH, 4 FILS					 UNIVERSITÉ <b>LAVAL</b> Service des immeubles		 WESTINGHOUSE Type PL-1 Classe N/A		WESTINGHOUSE Type PL-1 TYPE DISJ. MARCHAND				
WATTS			DISJ.											DISJ.	WATTS		
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC				
				PC Plafond 00242-A	15 DDFT	1	2	15	PC 00244-00242-A (U:B6)								
				PC Plafond 00244 (U:B6)	15 DDFT	3	4	15	PC 00236-00241								
				PC 00242-A (Microscope)	15	5	6	15	PC 00236-00241								
				PC 00256 (Désinfection)	15	7	8	15	PC 00246-00248 (Atelier)								
				PC 00256 (Cuve atelier)	15	9	10	15	PC 00244 (U:B6)								
				PC 00256 (Désinfection)	20	11	12	30	PC 00256 (Désinfection)								
				PC 00256 (Désinfection)	20	13	14	30	PC 00256 (Cuve)								
				LIBRE	15	15	16	20	PC 00256 (Cuve)								
				"	15	17	18	20	PC 00256 (Cuve)								
				PC 00242-A	30	19	20	30	Ventilo-Convecter								
				Thermopompe	30	21	22	30	Loc 00246 (U:B7)								
				"	30	23	24	20 DDFT	Élément Chauffant								
				Chauf/REF	20 DDFT	25	26	20 DDFT	Loc 00246 (U:B7)								
				00201 (Procédé U:B6)	20 DDFT	27	28		ESPACE								
				ESPACE	30	29	30		ESPACE								
				LIBRE	15	31	32	40	LIBRE								
				"	15	33	34	40	LIBRE								
				"	15	35	36	40	LIBRE								
				"	15	37	38	15	LIBRE								
				ESPACE		39	40		ESPACE								
				"		41	42		"								
0	0	0		TOTAL		0					0	0	0				