

WATTS				DISJ.				MDE-PP-1-1631 225 Amperes 347/600 VOLTS 3 PH, 4 FILS				UNIVERSITÉ LAVAL Service des immeubles				WESTINGHOUSE NFB Classe N/A MEDECINE DENTAIRE				DISJ.				WATTS			
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC									
				ÉCL. 1752	15	1	2	15	Écl. 1748, 1747, 1720, 1751-C, 1759, 1772																		
				ÉCL. 1758	15	3	4	15	Écl. 1751-A, 1751-B, 1776, 1725, 1755																		
				ÉCL. 1766, 1760, 1770, 1762, 1764	15	5	6	15	Écl. 1716-A, 1716-B, 1722-A, 1722-B																		
				ÉCL. 1728-A, 1732, 1787-A,	15	7	8	15	Écl. 1615-C, 1615-B, 1615-E, 1616, 1617, 1619, 1623																		
				Écl. Passage	15	9	10	15	Écl. 1615-A, 1615-B																		
				"	15	11	12	15	VENT-CEN-1298 TOIT																		
				LIBRE	30	13	14	15	DEMA-VENT-CEN-1298																		
				"	30	15	16	15	Local 1751C																		
				"	30	17	18	20	Écl. Passage 1565 & 1511																		
				FAN TOIT	15	19	20	15	Transfo. À relais																		
				UM 2589A et B	15	21	22	15	Occupé																		
				DEMA-VENT-CEN-1297 et 1296	15	23	24		ESPACE																		
						25	26																				
						27	28																				
						29	30																				
						31	32																				
						33	34																				
						35	36																				
						37	38																				
						39	40																				
						41	42																				
0	0	0		TOTAL		0					0	0	0														