

				VCH-CDPU-2-00200					Westinghouse CDP								
				400 A					UNIVERSITÉ LAVAL								
				600 Volts					Service des immeubles								
				3 PH, 3 FILS					Classe N/A								
				Vachon													
WATTS				DISJ.					DISJ.					WATTS			
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC				
				LIBRE	15	1	2	15	Libre								
				LIBRE	15	3	4	15	Libre								
				LIBRE	15	5	6	15	Libre								
				LIBRE	60	7	8	15	Asc. 5-6-7-8-9								
				LIBRE	60	9	10	15	Asc. 5-6-7-8-9								
				LIBRE	60	11	12	15	Asc. 5-6-7-8-9								
				LIBRE	30	13	14	70	SECTU-1-00065								
				LIBRE	30	15	16	70	SECTU-1-00065								
				LIBRE	30	17	18	70	SECTU-1-00065								
				DEMAU-POMP-CEN-417	30	19	20	30	Booster UM-29700								
				ET	30	21	22	30	Booster UM-29700								
				DEMAU-POMP-CEN-418	30	23	24	30	Booster UM-29700								
				LIBRE	30	25	26	30	V.8.9								
				LIBRE	30	27	28	30	V.8.9								
				LIBRE	30	29	30	30	V.8.9								
				Pompe 9-10-11	30	31	32	30	Compresseur UM-29670								
				Pompe 9-10-11	30	33	34	30	Compresseur UM-29670								
				Pompe 9-10-11	30	35	36	30	Compresseur UM-29670								
				Pompes 1-2-3	30	37	38	30	TR/U-1-00200								
				Pompes 1-2-3	30	39	40	30	TR/U-1-00200								
				Pompes 1-2-3	30	41	42	30	TR/U-1-00200								
0	0	0		TOTAL		0					0	0	0				

				VCH-CDPU-2-00200					UNIVERSITÉ LAVAL		Westinghouse CDP						
				400 A					Service des immeubles		Classe N/A		Vachon				
				600 Volts									DISJ.		WATTS		
				3 PH, 3 FILS													
WATTS		DISJ.															
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC				
				Pompe 4	30	43	44	30	SECTU-1-VCH-AS11								
				Pompe 4	30	45	46	30	ATRIUM								
				Pompe 4	30	47	48	30	LOCAL 00131								
				TRU-1-3037<	40	49	50	30	LIBRE								
				TRU-1-3037<	40	51	52	30	LIBRE								
				TRU-1-3037<	40	53	54	30	LIBRE								
				Pompes 5-6-7-8	50	55	56	40	LIBRE								
				Pompes 5-6-7-8	50	57	58	40	LIBRE								
				Pompes 5-6-7-8	50	59	60	40	LIBRE								
				LIBRE	50	61	62	15	LIBRE								
				LIBRE	50	63	64	15	LIBRE								
				LIBRE	50	65	66	15	LIBRE								
				LIBRE	15	67	68	15	Asc. 1-2-3-4								
				LIBRE	15	69	70	15	Asc. 1-2-3-4								
				LIBRE	15	71	72	15	Asc. 1-2-3-4								
				ESPACE		73	74	225	SECTU-2-0241								
				ESPACE		75	76	225	SECTU-2-0241								
				ESPACE		77	78	225	SECTU-2-0241								
0	0	0		TOTAL		0					0	0	0				