



				*CDSU-1-0241 600 A 120/208 Volts 3 PH, 4 FILS					 UNIVERSITÉ LAVAL Service des immeubles		 Westinghouse CDP Classe N/A					
WATTS		DISJ.							Vachon		DISJ.		WATTS			
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC			
				PC 0066	15	1	2	15	PC 0066							
				PC 0066	15	3	4	15	PC 0066							
				PC 0066	15	5	6	15	PC 0066							
				PC 0066	15	7	8	15	PC 0066							
				PC 0066	15	9	10	15	PC 0066							
				PC 0066	15	11	12	15	PC 0066							
				PC 0066	15	13	14	15	PC 0066							
				PC 0066	15	15	16	15	PC 0066							
				PC 0066	15	17	18	15	PC 0066							
				PC 0066	15	19	20	15	PC 0066							
				PC 0066	15	21	22	15	Alimentation alarme incendie 0245							
				PC 0066	15	23	24		ESPACE							
				alarme incendie 0245	15	25	26		ESPACE							
				ESPACE		27	28		ESPACE							
				LIBRE	15	29	30	15	LIBRE							
				LIBRE	15	31	32	15	LIBRE							
				LIBRE	15	33	34	15	LIBRE							
				LIBRE	15	35	36	30	Incubateur #2							
				LIBRE	15	37	38	30	" "							
				LIBRE	15	39	40	30	" "							
				LIBRE	30	41	42	30	Incubateur #3							
0	0	0		TOTAL		0					0	0	0			

VCH-CDSU-1-0241
 600 A
 120/208 Volts
 3 PH, 4 FILS



Service des immeubles



Classe

N/A

Westinghouse
 CDP

Vachon

WATTS				DISJ.				WATTS				DISJ.			
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC		
				LIBRE	30	43	44	30	Incubateur #3						
				LIBRE	30	45	46	30	" "						
				Chambre #5	50	47	48	40	Incubateur #1						
				" "	50	49	50	40	" "						
				" "	50	51	52	40	" "						
				Chambre #4	50	53	54	50	Chambre #6						
				" "	50	55	56	50	" "						
				" "	50	57	58	50	" "						
				LIBRE	70	59	60	90	Grande chambre						
				LIBRE	70	61	62	90	" "						
				LIBRE	70	63	64	90	" "						
						65	66								
						67	68								
						69	70								
						71	72								
0	0	0		TOTAL		0					0	0	0		