

				VND-PS-1-1294 225 AMPS 120/208 V 3 PH, 4 FILS					 UNIVERSITÉ LAVAL Service des immeubles		 Classe N/A		SIEMENS TYPE P2 BL					
WATTS		DISJ.							PAVILLON VANDRY		DISJ.		WATTS					
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC					
1 600				PC (MC) 1289A	20	1	2	20	PC 1250G-1289A				1 200					
1600				PC (MC) 1289A	20	3	4	20	PC 1250C-1250F-1289A				1600					
600				PC PLAF. 1289A	15	5	6	20	PC (MC) 1269				1600					
625				PC 1289A	15	7	8	20	PC (MC) 1269				1600					
625				PC 1289A	15	9	10	15	PC PLAF. 1269				600					
625				PC 1289A	15	11	12	15	PC 1269				600					
1600				PC 1287	20	13	14	20	PC 1294				1600					
1600				PC 1287	20	15	16	20	PC 1294				1600					
300				PC PLAF. 1287	15	17	18	20	PC 1296				1600					
750				PC 1287-1287A	15	19	20	20	PC 1296				1600					
1600				PC 1295	20	21	22	15	PC PLAF. 1294-1296				600					
1600				PC 1295	20	23	24	15	PC 1296				500					
300				PC PLAF. 1295	15	25	26	15	PC 1294				500					
625				PC 1295-1295A	15	27	28	15	PC 1267 (DFT)				375					
1460				PC 1263 SM	15	29	30	15	PC 1267 SM				1460					
						31	32											
1460				PC 1263 SM	15	33	34		ESPACE									
						35	36		ESPACE									
				RM #1250C-124-1401	15	37	38	15	PC 1250C				300					
				ESPACE		39	40	15	LIBRE									
				ESPACE		41	42		ESPACE									
16970	0	0		TOTAL		34305					0	0	17335					

VND-PS-1-1294
225 AMPS
120/208 V
3 PH, 4 FILS



SIEMENS
TYPE P2
BL

PAVILLON VANDRY

DISJ.

WATTS

WATTS				DISJ.				WATTS					
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC
				ESPACE		43	44		ESPACE				
				ESPACE		45	46		ESPACE				
				ESPACE		47	48		ESPACE				
				ESPACE		49	50		ESPACE				
				ESPACE		51	52		ESPACE				
				ESPACE		53	54		ESPACE				
0	0	0		TOTAL		0					0	0	0