



				DKN-PS-1-00147 225A-10kA 120/208V 3PH, 4FILS					 UNIVERSITÉ LAVAL Service des immeubles		 Classe N/A		SIEMENS P1 BL					
WATTS			DISJ.						De Koninck		DISJ.	WATTS						
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC					
	192			ÉCL. 00147	15	1	2	20	PC 00147				500					
		617		VENT-CON-1813 LOCAL 00147<	15	3	4	15	VENT-CON-1976 LOCAL 00145<		387							
		387		VENT-CON-1977 LOCAL 00149<	15	5	6	15	VENT-CON-1987 LOCAL 00157		208							
		30		VENT-CEN-1785 LOCAL 00157	15	7	8	20	PORTE MOTREC 00157		617							
		617		PORTE MOTREC 00157	20	9	10	20	2xPC CORRIDOR NORD				1000					
500				PC CORRIDOR NORD	20	11	12	15	3xPC 00137-00139- 00141				360					
240				2xPC 00143-00145	15	13	14	15	3xPC 00149-00151- 00153				360					
	768			ÉCL. CORRIDOR NORD + 00135-00161	15	15	16	15	ÉCL. 00137-39-41-43-45- 45A-49-51-53-57			1280						
				LIBRE	20	17	18	20	LIBRE									
				LIBRE	20	19	20	15	LIBRE									
				LIBRE	15	21	22	15	LIBRE									
				LIBRE	15	23	24	15	LIBRE									
				LIBRE	15	25	26	15	LIBRE									
				LIBRE	15	27	28	15	LIBRE									
				LIBRE	15	29	30	15	LIBRE									
						31	32											
						33	34											
						35	36											
						37	38											
						39	40											
						41	42											
740	960	1651		TOTAL	8063						1 212	1280	2220					