



				DKN-PS-1-3215< 200 A. 120 / 208 V. 3 PH, 4 FILS					  Université Laval Service des immeubles Classe N/A Westinghouse NPLB De Koninck								
WATTS		DISJ.												DISJ.		WATTS	
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC				
				Lumière 6203	15	1	2	15	PC 15A 6203, 05, 07, 09, 11, 13								
				Lumière 6203, 05, 07	15	3	4	15	PC 15A 6211, 13								
				Lumière 6209, 11, 13	15	5	6	15	PC 15A 6215, 17, 19, 21								
				Lumière 6215, 17, 19	15	7	8	15	PC 15A 6223, 25								
				Lumière 6221, 23, 25	15	9	10	15	PC 15A 4203								
				Transformer Remote control	15	11	12	15	Lumière galerie 4½								
				Lumière 4203, 3023	15	13	14	30	PC 30A galerie 4½								
				Lumière 4203, 05, 07	15	15	16	20	PC 20A galeire 4½ près du 6211								
				Lumière 4209, 11, 13	15	17	18	20	PC 20A galeire 4½ près du 6217								
				Lumière 4215, 17, 18	15	19	20	30	Lumière galerie 3½								
				Lumière 4221, 23, 25	15	21	22	30	PC 30A galerie 3½								
				PC 15A 4203, 05, 07, 09	30	23	24	30	" "								
				PC 30A Galerie	15	25	26	15	PC 15A 3215, 17, 19, 21								
				PC 15A 3225	15	27	28	15	PC 15A 4211, 13 Panneau tél. 115V								
				PC 15A 3203	15	29	30	15	PC 15A 4215, 17, 19, 21								
				Fluo 3201, 03, 15	15	31	32	15	PC 15A 3203, 13								
				Lumière 3203	15	33	34	15	PC 15A 4223, 25								
				Lumière 3213	15	35	36	15	Lumière passage								
				Lumière 3219, 21, 25	15	37	38	15	PC 3207								
				Lumière 3225 PC 3206	15 15	39	40	15	Libre								
				PC 3223	15	41	42	15	" "								
0	0	0		TOTAL	0						0	0	0				