

				DKN-PS-1-3413< 200 A 120/208 Volts 3 PH, 4 FILS					 UNIVERSITÉ LAVAL Service des immeubles		 Westinghouse NPLB Classe N/A					
WATTS		DISJ.							De Koninck		DISJ.		WATTS			
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC			
				Lum. 6403	15	1	2	15	PC 15A 6403-05-07-09							
				Lum. 6405-07	15	3	4	15	PC 15A 6411-13-15-17- panneau téléphone							
				Lum. 6409-11-13	15	5	6	15	PC 15A 6421-23							
				Lum. 6415-17-21	15	7	8	15	PC 15A 6423							
				Lum. 6421-23	15	9	10	15	PC 15A 6403-4403- 3403							
				Lum. 6423	15	11	12	15	Lum. Galerie 4½							
				Lum. 4403	15	13	14	30	Pc 30A galerie 4½							
				Lum. 4405-07	15	15	16	30	Pc 30A galerie 4½							
				Lum. 4409-11-13	15	17	18	30	Pc 30A galerie 4½							
				Lum. 4415-17-19	15	19	20	15	Lum. Galerie 3½							
				Lum. 4421-23-25	15	21	22	30	PC 30A galerie 3½							
				Pc 15A 4409-07-05-03	15	23	24	30	PC 30A galerie 3½							
				PC 20A galerie 3½	20	25	26	15	PC 15A 3415-17-21							
				PC 15A 3421	15	27	28	15	PC 15A 4413-11							
				PC 15A 3403	15	29	30	15	PC 15A 4421-19-17-15							
				Lum. 3403	15	31	32	15	PC 15A 3403-13							
				Lum. 3403	15	33	34	15	PC 15A 4425-23-19							
				Lum. 3413-15-17	15	35	36	15	Lum. Passage							
				Lum. 3421-17	15	37	38	15	Transformateur remote control no.6 poinçon							
				LIBRE	15	39	40	15	OCCUPÉ							
				LIBRE	15	41	42	20	PC 20A 3401							
0	0	0		TOTAL	0						0	0	0			