



| | | | | DKN-PS-2-5138 225 Ampères 120/208 VOLTS 3 PH, 4 FILS | | | | |  UNIVERSITÉ LAVAL Service des immeubles | |  WESTINGHOUSE Type PL-1 Classe N/A | | | | | |
|-------|------|----|------------|---|-----|------|------|-----|--|------------|---|------|----|--|--|--|
| WATTS | | | DISJ. | | | | | | DE KONINCK | DISJ. | WATTS | | | | | |
| PC | ÉCL. | HP | MODEL / KA | DESCRIPTION | CAL | CIRC | CIRC | CAL | DESCRIPTION | MODEL / KA | HP | ÉCL. | PC | | | |
| | | | | PC 5137D | 20 | 1 | 2 | 20 | PC 5137-D | | | | | | | |
| | | | | PC 5137D | 20 | 3 | 4 | 20 | PC 5137-D | | | | | | | |
| | | | | PC 5137D | 20 | 5 | 6 | 15 | PC 5126 | | | | | | | |
| | | | | PC 5137D | 20 | 7 | 8 | 15 | PC 5126 | | | | | | | |
| | | | | PC 5138 | 15 | 9 | 10 | 20 | PC 5188 | | | | | | | |
| | | | | PC 5138 | 15 | 11 | 12 | 20 | PC 5188A | | | | | | | |
| | | | | PC 5138 | 15 | 13 | 14 | 15 | LIBRE | | | | | | | |
| | | | | VENT-CEN-1231 LOCAL 5137D | 15 | 15 | 16 | 15 | PC 5118 (Micro-onde) | | | | | | | |
| | | | | LIBRE | 15 | 17 | 18 | 15 | PC 5118 (Micro-onde) | | | | | | | |
| | | | | PC 5206 | 20 | 19 | 20 | 20 | PC 5206 | | | | | | | |
| | | | | PC 5206 | 20 | 21 | 22 | 20 | PC 5206 | | | | | | | |
| | | | | PC 5206 | 20 | 23 | 24 | 20 | PC 5206 | | | | | | | |
| | | | | PC 5206 | 15 | 25 | 26 | 15 | PC 5118 (Micro-onde) | | | | | | | |
| | | | | LIBRE | 20 | 27 | 28 | 15 | PC 5118 (Frigo) | | | | | | | |
| | | | | LIBRE | 20 | 29 | 30 | 15 | LIBRE | | | | | | | |
| | | | | PC 5150 | 20 | 31 | 32 | 20 | PC 5137D (DTI) | | | | | | | |
| | | | | PC 5150 | 20 | 33 | 34 | 20 | PC 5137D (DTI) | | | | | | | |
| | | | | PC 5150 | 15 | 35 | 36 | | ESPACE | | | | | | | |
| | | | | ESPACE | | 37 | 38 | | ESPACE | | | | | | | |
| | | | | ESPACE | | 39 | 40 | | ESPACE | | | | | | | |
| | | | | ESPACE | | 41 | 42 | | ESPACE | | | | | | | |
| 0 | 0 | 0 | | TOTAL | | 0 | | | | | 0 | 0 | 0 | | | |

RÉFÉRENCE SEULEMENT