



				DKN-CDS-1-00107 600A-10kA 120/208V 3PH, 4FILS					 UNIVERSITÉ LAVAL <small>Service des immeubles</small>		 Classe N/A		Siemens P2 BL DeKoninck					
WATTS		DISJ.							DISJ.		WATTS							
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC					
45 940				DKN-PS-1-1153	250	1	2	125	DKN-PS-1-3153				19424					
				FEEDTHROUGH	250	3	4	125	"									
				DKN-PS-1-2153	250	5	6	125	"									
				LIBRE	70	7	8		ESPACE									
				"	70	9	10		ESPACE									
				"	70	11	12		ESPACE									
		617		VENT-CON-1809 LOCAL 00106<	15	13	14	25	VENT-CON-1810 LOCAL 00104Z<		1200							
		1200		VENT-CON-1811 LOCAL 00104Z<	25	15	16	25	VENT-CON-1812 LOCAL 00104Z<		1200							
				ESPACE		17	18		ESPACE									
				"		19	20		"									
				"		21	22		"									
				"		23	24		"									
				"		25	26		"									
				"		27	28		"									
				"		29	30		"									
				"		31	32		"									
				"		33	34		"									
				"		35	36		"									
				"		37	38		"									
				"		39	40		"									
				"		41	42		"									
45940	0	1817		TOTAL		69581					2 400	0	19424					

