



				PSA-PS-2-1848A 225 A. 120/208 V. 3 PH, 4 FILS		 UNIVERSITÉ LAVAL Service des immeubles		 Classe N/A		Cutler Hammer PRL1A I.N.A.F.			
WATTS		DISJ.								DISJ.		WATTS	
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC
				Ecl. 1848	20	1	2	20	Ecl. 1848A,34,26a,16				
				Ecl. 1848	20	3	4	20	Ecl. 1831				
				Ecl. 1848	20	5	6	20	Ecl. 1845,07,12 0842A,68,42,01A,40				
				Ecl. 1848	20	7	8	20	Ecl. 1856, 54				
				Ecl. 1848	20	9	10	20	Ecl. 0851, 0838				
				Ecl. Extérieur	20	11	12	20	Ecl. 0861, 0830				
				PC 1848	20	13	14	20	Ecl. 0817, 0815				
				PC 1848	20	15	16	20	PC 1848A				
				PC 1848	20	17	18	15	PC 1834				
				PC 1848	20	19	20	15	PC 1834,26A				
				PC 1848	20	21	22	20	PC 1807 Corr.				
				PC 1848	20	23	24	30	Sableuse 1831				
				PC 1848	20	25	26	20	Meule 1831				
				PC 1848	20	27	28	20	Meule,item 14, 1831				
				PC 1848	20	29	30	30	Perceuse, item 15, 1831				
				PC 1848	20	31	32	30	Capt. Fumée, item 22				
				PC 1848	30	33	34	20	PC comptoir 1826				
				" "	30	35	36	20	PC comptoir 1826				
				PC 1848	20	37	38	30	Sableuse, item 6,1826				
				Banc de Scie, Item 9	30	39	40	15	PC exterieure				
				LIBRE	20	41	42	15	PC exterieure				
0	0	0		TOTAL		0					0	0	0

