

				PLT-PS-2-2534 200 A 110/220 Volts 1 PH, 3 FILS					 UNIVERSITÉ LAVAL <small>Service des immeubles</small>		 Westinghouse NPLB Classe N/A					
WATTS		DISJ.							Westinghouse NPLB		DISJ.		WATTS			
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC			
				OCCUPÉ	15	1	2	15	OCCUPÉ							
				" "	15	3	4	15	" "							
				Éclairage 2508	15	5	6	15	" "							
				PC pass. 2510 + loc. 2505	15	7	8	15	Éclairage 2500							
				PC 2508+10 mur ext.	15	9	10	15	OCCUPÉ							
				PC loc. 2708 + p. esc	20	11	12	15	Éclair. 2504							
				PC 2500, 2504 (mur ext.)	15	13	14	15	PC 2504							
				PC pass. 2500-10-12	15	15	16	15	PC 2504							
				PC 2510,2508 mur ext.	15	17	18	15	OCCUPÉ							
				LIBRE	20	19	20	15	Prise concierge							
				" "	20	21	22	15	MEUBLE 2505							
				" "	20	23	24	15	LIBRE							
				" "	20	25	26	15	" "							
				PC 2512	15	27	28	15	" "							
				PC 2512	15	29	30	15	" "							
				PC 2512	15	31	32	15	" "							
				PC 2512	15	33	34	15	" "							
				LIBRE	15	35	36	15	" "							
				" "	15	37	38	15	" "							
				" "	15	39	40	15	" "							
				ESPACE		41	42		ESPACE							
0	0	0		TOTAL		0					0	0	0			