



				DKN-PS-1-2106 225A-10kA 120/208V 3PH, 4FILS					 UNIVERSITÉ LAVAL Service des immeubles		 Classe N/A		Siemens P1 Next Gen BL De Koninck					
WATTS		DISJ.												DISJ.		WATTS		
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC					
1 000				2xPC 2102-2104	20	1	2	15	TRANSFOS CONTROLE TOILETTES 2102-2104				200					
120				FONT-EAU-284 2407<	15	3	4	15	3xPC 2107-2109-2111				360					
360				3xPC 2107-2109-2111	15	5	6	15	3xPC 2107-2109-2111				360					
360				3xPC 2113-2115-2119	15	7	8	15	3xPC 2113-2115-2119				360					
360				3xPC 2113-2115-2119	15	9	10	15	2xPC 2121-2122				240					
240				2xPC 2121-2122	15	11	12	15	2xPC 2121-2122				240					
240				2xPC 2114-2120	15	13	14	15	2xPC 2114-2120				240					
240				2xPC 2114-2120	15	15	16	15	PC 2100				120					
1000				2xPC CORR. NORD SECTION OUEST	20	17	18	20	PC 2112				500					
	744			ECL. 2107-07A-09-11 13-14-15-19-20-21-22	15	19	20	15	ECL. CORR. NORD SECTION OUEST			205						
	233			ÉCL. 2100-2102-2104	15	21	22	15	ÉCL. 2101-2112			448						
				LIBRE	20	23	24	20	LIBRE									
				LIBRE	15	25	26	15	LIBRE									
				LIBRE	15	27	28	15	LIBRE									
				LIBRE	15	29	30	15	LIBRE									
				LIBRE	15	31	32	15	LIBRE									
				LIBRE	15	33	34	15	LIBRE									
				LIBRE	15	35	36	15	LIBRE									
				TVSS	30	37	38											
				TVSS	30	39	40											
				TVSS	30	41	42											
3920	977	0		TOTAL	8170						0	653	2620					