





				FAS-PPU-1-0092 225 Ampères 347/600 VOLTS 3 PH, 4 FILS					 					
WATTS			DISJ	Service des immeubles F-A.SAVARD (tour #2)					DISJ	WATTS				
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC	
			ED63B050 18kA	SECT/U-1-1729	50	1	2	50	SECT/U-4-C0210	ED63B50 18kA				
				SECT/U-1-1729	50	3	4	50	"					
				SECT/U-1-1729	50	5	6	50	"					
			ED63B050 18kA	LIBRE	50	7	8	50	DEMAU-POMP-SUR-	ED63B50 18kA				
				"	50	9	10	50	4/5					
				"	50	11	12	50	(LOCAL 0092)					
			ED63B050 18kA	TR/U-1-0092	50	13	14	30	UM-13390	ED63B50 18kA				
				"	50	15	16	30	Syst. 11, 1729					
				"	50	17	18	30	"					
			ED63B030 18kA	LIBRE	30	19	20	20	LIBRE	ED63B50 18kA				
				"	30	21	22	20	"					
				"	30	23	24	20	"					
			ED63B020 18kA	LIBRE 0082	20	25	26	20	UM-1301	ED63B50 18kA				
				LIBRE 0082	20	27	28	20	UM-1302					
				LIBRE 0082	20	29	30	20	Po. Pluvial					
			ED63B050 18kA	UM-1306	15	31	32	15	DEMAU-POMP-APP-6	ED63B50 18kA				
				UM-1307	15	33	34	15	Local 0012					
				Po. Cond.	15	35	36	15	"					
			ED63B015 18kA	LIBRE dans	15	37	38	15	LIBRE	ED63B50 18kA				
				LOCAL 1729	15	39	40	15	"					
				"	15	41	42	15	"					
0	0	0		TOTAL		0					0	0	0	

				<b>FAS-PPU-1-0092</b> <b>225 Ampères</b> <b>347/600 VOLTS</b> <b>3 PH, 4 FILS</b>					 <b>UNIVERSITÉ LAVAL</b> <small>Service des immeubles</small>		 <b>SIEMENS</b> <b>Type SENTRON</b>					
<b>WATTS</b>		<b>DISJ</b>							<b>DISJ</b>		<b>WATTS</b>					
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC			
				ESPACE		43	44	70	CVP/U-1-C02010	ED60B070 18kA						
				"		45	46	70	"							
				"		47	48	70	"							
0	0	0		TOTAL		0					0	0	0			

RÉFÉRENCE SEULEMENT