



				DKN-PS-1-3443 225 A 120/208 Volts 3 PH, 4 FILS					  Université Laval Service des immeubles Classe N/A Westinghouse NBA De Koninck								
WATTS		DISJ.												DISJ.		WATTS	
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC				
				PC 3449-53-57	15	1	2	15	PC 3469-74								
				PC 3457-59-61	15	3	4	15	PC 3471-75								
				PC 3449	15	5	6	15	PC 3447								
				PC 3439A (DTI)	20	7	8	20	PC 20A 125 V 3493-93A								
				PC 3439A (DTI)	20	9	10	15	PC 3445-43								
				PC 3439A (DTI)	20	11	12	15	PC 3441-43								
				PC 3439A (DTI)	20	13	14	20	PC 3439A (DTI)								
				PC 3439A (DTI)	20	15	16	20	PC 3439A (DTI)								
				PC 3439A (DTI)	20	17	18	20	PC 3401A (DTI)								
				PC 3401A (DTI)	20	19	20	20	PC 3401A (DTI)								
				PC 3401A (DTI)	20	21	22	20	PC 3401A (DTI)								
				PC 3401A (DTI)	20	23	24	20	PC 3401A (DTI)								
				PC 3401A (DTI)	20	25	26	15	LIBRE								
				LIBRE	15	27	28	15	LIBRE								
				LIBRE	15	29	30	15	LIBRE								
				PS-1-4443<	70	31	32	15	LIBRE								
				PS-1-4443<	70	33	34	15	LIBRE								
				PS-1-4443<	70	35	36	15	LIBRE								
				PS-1-6443<	70	37	38	15	LIBRE								
				PS-1-6443<	70	39	40	15	LIBRE								
				PS-1-6443<	70	41	42	15	LIBRE								
0	0	0		TOTAL		0					0	0	0				