

				DKN-PS-1-3444< 225 A 120/208 Volts 3 PH, 4 FILS					 UNIVERSITÉ LAVAL <small>Service des immeubles</small>		 Classe N/A		Siemens P1 Next Gen BL De Koninck					
WATTS		DISJ.							DISJ.		WATTS							
PC	ÉCL.	HP	MODEL / KA	DESCRIPTION	CAL	CIRC	CIRC	CAL	DESCRIPTION	MODEL / KA	HP	ÉCL.	PC					
				PC 3456H	20 20	1	2	20	PC Passage 3422									
				PC 3456H	15	3	4	20 20	OCCUPÉ									
				PC 3456H	15	5	6	15	OCCUPÉ									
				OCCUPÉ	20 20	7	8	15	PC Fontaine									
				OCCUPÉ	20 20	9	10	30	OCCUPÉ									
				OCCUPÉ	15	11	12	30	LIBRE									
				OCCUPÉ	15	13	14	30	LIBRE									
				OCCUPÉ	15	15	16	15	PC DDFT S.Bain									
				OCCUPÉ	20	17	18	15	PC 3456B									
				OCCUPÉ	15	19	20	15	OCCUPÉ									
				PS-2-3443	70	21	22	15	OCCUPÉ									
				PS-2-3443	70	23	24	15	OCCUPÉ									
				PS-2-3443	70	25	26	20	LIBRE									
				OCCUPÉ	15	27	28	30	OCCUPÉ									
				LIBRE	20	29	30	30	OCCUPÉ									
						31	32											
						33	34											
						35	36											
						37	38											
						39	40											
						41	42											
0	0	0		TOTAL		0					0	0	0					

RÉFÉRENCE SEULEMENT